



**NOTES:**

1. ROOT PROTECTION MATTING (RPM) SHALL BE SUPERVISED BY AN ISA CERTIFIED ARBORIST.
2. MATTING MATERIAL SHALL BE DOUBLE SIDED GEOCOMPOSITE, GEONET CORE WITH NON-WOVEN COVERING (SUCH AS TENAX TENDRAIN 770/2) OR APPROVED EQUIVALENT.
3. TO BE USED FOR DESIGNATED TEMPORARY CONSTRUCTION ACCESS AND STOCKPILE AREAS.
4. MATTING SHALL BE PLACED ON 4"-6" WOOD CHIP MULCH UNLESS OTHERWISE DIRECTED.
5. FOR HEAVY TRAFFIC AREAS, MATTING SHALL BE COVERED WITH 6"-8" WELL GRADED CRUSHED AGGREGATE. ADDITIONAL LAYERS OF GEOTEXTILE MAY BE NEEDED.



**Department of Public Works**  
**10455 Armstrong Street**  
**Fairfax, VA 22030-3630**

**CITY of FAIRFAX**

**USE WITH THE FAIRFAX STANDARD SPECIFICATIONS ONLY**

[www.fairfaxva.gov](http://www.fairfaxva.gov)

**TEMPORARY ROOT PROTECTION MATTING WITHIN CRZ**

SCALE: NOT TO SCALE	TP-03
REVISION DATE: JULY 2024	SHEET #: 1 of 1